

**MOST FREQUENTLY CITED STANDARDS IN CONSTRUCTION
INSPECTIONS OPENED BETWEEN JANUARY 1, 2019 – DECEMBER 31, 2019**

Rank	Standard	Description	Times Cited
1	1926.501(b)(13)	FALL PROTECTION NOT PROVIDED FOR RESIDENTIAL CONSTRUCTION ACTIVITIES	17
2	1926.503(a)(1)	FALL PROTECTION TRAINING NOT PROVIDED	12
3	1926.416(a)(1)	EMPLOYEES WORKING TOO CLOSE TO ENERGIZED ELECTRICAL PARTS	8
4	1926.453(b)(2)(v)	FALL PROTECTION NOT PROVIDED FOR EMPLOYEES WORKING ON AERIAL LIFTS	8
5	1926.20(b)(2)	NO PROGRAM PROVIDING FOR FREQUENT AND REGULAR INSPECTIONS OF WORKSITES BY A COMPETENT PERSON.	6
6	1926.416(a)(3)	EMPLOYER FAILED TO ASSESS ELECTRICAL HAZARDS AND/OR NOTIFY EXPOSED EMPLOYEES.	6
7	1926.501(b)(1)	FALL PROTECTION NOT PROVIDED FOR EMPLOYEES WORKING AT HEIGHTS OF 6 FEET OR MORE.	6
8	1926.21(b)(2)	EMPLOYEES NOT INSTRUCTED IN BASIC HAZARD RECOGNITION AND AVOIDANCE OF UNSAFE CONDITIONS.	5
9	1926.451(b)(1)	SCAFFOLD PLATFORMS NOT FULLY PLANKED OR DECKED BETWEEN THE FRONT UPRIGHTS AND THE GUARDRAIL SUPPORTS.	5
10	1926.501(b)(10)	FALL PROTECTION NOT PROVIDED FOR ROOFING ACTIVITIES ON LOW-SLOPE ROOFS.	5