



SC Occupational Safety and Health Administration

25 MOST FREQUENTLY CITED CONSTRUCTION STANDARDS

January 1, 2016- December 31, 2016

Rank	# Cited	Standard	Hazard Description
1	36	1910.1200(h)(1)	Inadequate training on hazardous chemicals
2	36	1926.501(b)(1)	Fall protection – unprotected sides and edges/residential construction
3	34	1910.1200(e)(1)(i)	No list of hazardous chemicals
4	33	1.12(a)	Failed to furnish a place of employment free of recognized hazards
5	32	1910.1200(e)(1)	No written hazard communication program
6	31	1910.1200(g)(1)	No safety data sheets for hazardous chemicals
7	26	1926.503(a)(1)	No fall protection training program
8	21	1926.453(b)(2)(v)	No body belt worn and lanyard attached when working from an aerial lift
9	17	1926.652(a)(1)	No protection from cave-ins for employees in an excavation
10	16	1910.212(a)(1)	Machinery not properly guarded
11	16	1926.451(g)(4)(i)	Inadequate guardrails on open sides and ends of scaffold platforms
12	13	1926.501(b)(13)	No fall protection for employees working above 6 feet in residential construction
13	13	3.39(a)	Not reporting a fatality, in-patient hospitalization, amputation, or a loss of an eye
14	11	1926.602(a)(9)(i)	No audible alarms for material handling equipment
15	11	1926.651(k)(1)	No daily inspection conducted by the competent person before each work shift
16	10	1926.304(g)(6)(vi)(c)(5)	No grounding provisions for appliances when used in damp or wet locations
17	10	1926.300(b)(2)	Unguarded reciprocating, rotating, or moving parts of equipment
18	9	1910.178(l)(4)(iii)	No evaluation of forklift operator's performance conducted every 3 years
19	9	1926.651(k)(2)	Competent person failed to remove employees from hazardous excavation area
20	8	1910.212(a)(3)(ii)	No guard provided for point of operation on machines
21	8	1926.21(b)(2)	No instructions provided to employees on hazard recognition and avoidance
22	8	1926.651(j)(2)	No protection from excavated or other materials or equipment
23	7	1910.147(c)(1)	No written control of hazardous energy (lockout/tagout) program
24	7	1926.405(b)(1)	Unused openings in cabinets, boxes, and fittings not effectively closed
25	7	1926.501(b)(4)(i)	No fall protection for employees on walking/working surfaces more than 6 feet

January 1, 2016- December 31, 2016